

- Translation -

No. TTW/599/17

October 24th, 2017

Subject : Explanation on the recent accident

Attention : President of The Stock Exchange of Thailand

In regard to the accident recently occurred within our Banglen's water treatment plant at 3.30 pm. on 20 October 2017, the Company would like to explain that the Maintenance Section has a plan to conduct machinery maintenance. The staff of this section then conducted such practice as scheduled. During the maintenance process, the check valve had to be removed from the high pressure transmission pipeline. While doing so, the mechanical coupling disconnected unexpectedly, then spurting out a great deal of high pressure water. As a result, this inevitable event caused one casualty.

The Company, then, took an immediate response to such event by fixing all equipment and machine so that they are now returning to normal. We would like to confirm that such accident did not cause the impact on our water treatment whatsoever.

Please be informed accordingly,

Very truly yours,
(Chaiwat Utaiwan)
Managing Director

Corporate Affairs Division

Tel. : 02-019-9490-9 Ext. 1106

Fax. : 02-420-6064